

TENDER FILE
TO THE LOCAL OPEN CALL FOR TENDERS
PAKSITAN-Muzaffargarh- 2022-001 (03)

Supply and Assembling of Water Filtration Plants of various capacities

Publication date: December 8, 2022

Deadline for reception of applications: December 15, 2022

Deadline for reception of tenders: December 15, 2022

Purchaser Identification

Name: Civil Society Human and Institutional Development Programme - CHIP
Person in charge of the contract: Mr. Muhammad Rafique
Address: CHIP House, Plot # 05, Street # 09, G-8/2, Islamabad
Tel /fax: +92-51-2250360 & 2280081 and 0333-5208223
Email: rafique@chip-pk.org
Website: www.chip-pk.org

Civil Society Human and Institutional Development Programme (CHIP) is a not-for-profit company created in October 2004 under Section 42 of the Companies Ordinance 1984 (now Companies Act 2017). CHIP is registered with Securities and Exchange Commission of Pakistan-SECP.

Purpose/Nature of the contract

To achieve the programs, Civil Society Human and Institutional Development Programme (CHIP) researches privileged suppliers who could supply/ onsite assemble under terms and conditions defined in an annual framework agreement, with following Items:

Water Filtration Plants in Tehsil Jatoi and Muzaffargarh, Punjab

- 4 RO plants of 1000 ltr/hr capacity for new water filtration plant sites
- UF to RO conversion of 1 plant at Ghairywahin (from the last phase WFP)
- Membrane cleaning of RO plant at Nohan wala (from the last phase WFP)
- 3 RO plant of 180 ltr/hr capacity for schools

BOQ of RO Plant 1000 Ltr/Hr

Location		Basti Rawan UC Kallarwali, Jatoi		
Total cost	(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)			
	3 Months operation and maintenance (excluding electricity charges)			
	Training session of operators and an operating manual (5x3 ft panaflex)			
	One year warranty of Plant items			
Required size of the plant	Height	4-5 ft		
	Length	5-7 ft		
	Width	2-3 ft		
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on Stainless Steel 304 frame (Skid), 50mmx 50 mmx 3mm, 8.0 g/cm ³ (complete chrome plated on joints with stopers on each end)		1
2	Feed Pump	2.1 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China	1
			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg		
4	Activated Carbon Filter	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1

	(Automatic backwash and resetting)	Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Media: Deno Germany	1
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m3/hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m3/hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	2.1 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China	1
			Model: CDLF Series.	
9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000 ltr/hr , Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1
		Size: L:40", Dia 8"		
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m3/hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m3/hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1

7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed on the wall with angle iron frame	General	1
11	Tool kit	6"Rigid full floating froged hook jaw pipe wrench with ductile plasti housing, 1 roll of flew rubberized water proof tape, pipe scrapper, 500 ml UPVC adhesive solution		1

BOQ of RO Plant 1000 Ltr/Hr				
Location		Basti Namurdi UC Rampur, Jatoi		
Total cost		(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)		
		3 Months operation and maintenance (excluding electricity charges)		
		Training session of operators and an operating manual (5x3 ft panaflex)		
		One year warranty of Plant items		
Required size of the plant		Height	4-5 ft	
		Length	5-7 ft	
		Width	2-3 ft	
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on Stainless Steel 304 frame (Skid), 50mmx 50 mmx 3mm, 8.0 g/cm ³ (complete chrome plated on joints with stopers on each end)		1
2	Feed Pump	2.1 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China	1
			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery. Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg	Pentair/Pall	1
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery. Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Pentair/Pall Media: Deno Germany	1 1
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	2.1 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China Model: CDLF Series.	1

9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000 ltr/hr , Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1
		Size: L:40", Dia 8"		
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m3/hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m3/hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed on the wall with angle iron frame	General	1
11	Tool kit	6"Rigid full floating froged hook jaw pipe wrench with ductile plasti housing, 1 roll of flew rubberized water proof tape, pipe scrapper, 500 ml UPVC adhesive solution		1

BOQ of RO Plant 1000 Ltr/Hr				
Location		Basti Khutu UC Bairband, Jatoi		
Total cost		(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)		
		3 Months operation and maintenance (excluding electricity charges)		
		Training session of operators and an operating manual (5x3 ft panaflex)		
Required size of the plant		One year warranty of Plant items		
		Height	4-5 ft	
		Length	5-7 ft	
		Width	2-3 ft	
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on Stainless Steel 304 frame (Skid), 50mmx 50 mmx 3mm, 8.0 g/cm3 (complete chrome plated on joints with stopers on each end)		1

2	Feed Pump	2.1 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranted New. Made in China	1
			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 13"×54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg		
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 13"×54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Media: Deno Germany	1
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	2.1 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China	1
			Model: CDLF Series.	
9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000 ltr/hr , Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1
		Size: L:40", Dia 8"		
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m ³ /hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m ³ /hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1

4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed on the wall with angle iron frame	General	1
11	Tool kit	6"Rigid full floating froged hook jaw pipe wrench with ductile plasti housing, 1 roll of flew rubberized water proof tape, pipe scrapper, 500 ml UPVC adhesive solution		1

BOQ of RO Plant 1000 Ltr/Hr				
Location		Basti Kharoos UC Rampur, Jatoi		
Total cost		(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)		
		3 Months operation and maintenance (excluding electricity charges)		
		Training session of operators and an operating manual (5x3 ft panaflex)		
		One year warranty of Plant items		
Required size of the plant		Height	4-5 ft	
		Length	5-7 ft	
		Width	2-3 ft	
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on Stainless Steel 304 frame (Skid), 50mmx 50 mmx 3mm, 8.0 g/cm3 (complete chrome plated on joints with stopers on each end)		1
2	Feed Pump	2.1 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China	1
			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg		
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 13"x54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. Inbuilt with rechargeable battery.		
		Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg		
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal)	2.1 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Warranted. Unboxing and assembling on site New. Made in China	1

	of TDS upto 6000 ppm)		Model: CDLF Series.	
9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000 ltr/hr , Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1
		Size: L:40", Dia 8"		
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m3/hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m3/hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed on the wall with angle iron frame	General	1
11	Tool kit	6"Rigid full floating froged hook jaw pipe wranch with ductile plasti housing, 1 roll of flew rubberized water proof tape, pipe scrapper, 500 ml UPVC adhesive solution		1

BOQ of RO Plant 1000 Ltr/Hr					
Replacement of the existng UF+Arsenic media plant with RO plant of 1000 Ltr/Hr capacity					
Basti Allahyar UC Ghairywahin, Muzaffargarh					
Total cost	(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)				
	3 Months operation and maintenance (excluding electricity charges)				
	Training session of operators and an operating manual (5x3 ft panaflex)				
	One year warranty of Plant items				
Required size of the plant	Height	4-5 ft			
	Length	5 ft			
	Width	2-3 ft			
Sr No	Items	Description	Model/Make	Qty.	Requirement
1	Frame	Reassembling of already existing frame. Stainless Steel 304 frame, 50mmx 50mmx 3mm, 8.0 g/cm3, Total assembly should not occupy space more than 5ftx3ft		1	Reassembling to adjust RO parts of the plant

2	Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1	Replacement
3	Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1	Replacement
4	High Pressure Pump	2.1 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm for	CNP Brand. Imported and Brand/Warranted. Unboxing and assembling on site New. Made in China	1	Required
			Model: CDLF Series.		
5	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting)	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000 ltr/hr, Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1	Required
6	RO membrane casing	R/O Fiber Glass FRP pressure vessel for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1	Required
7	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3	Required
8	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2	Required
9	Flow meter	Flowmeter for product water	Taiwan	1	Required
10	Flow meter	Flowmeter for reject water	Taiwan	1	Required
11	Fittings	UPVC 80 schedule	Approved brand	1	New fittings required
Blending Line					
1	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1	Required
Cleaning of the plant					
1	Overall cleaning of the plant	Cleaning of plant including water tanks and water supply pipes		1	Required
Instrumentation and Controls					
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1	Required readjustment for RO
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2	Required readjustment for RO
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1	Required readjustment for RO
4	Float switch	On raw water tak for submercible pump	Approved brand	1	Required
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1	Required
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1	Required
9	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed on the wall with angle iron frame	General	1	Required
10	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2	Required readjustment for RO

BOQ of RO Plant 1000 Ltr/Hr					
Descaling and cleaning of RO membrane					
Basti Bhattiyan UC Nohan wala, Muzaffargarh					
Total cost	(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)				
	3 Months operation and maintenance (excluding electricity charges)				
	Training session of operators and an operating manual (5x3 ft panaflex)				
	One year warranty of Plant items				
Required size of the plant	Height	4-5 ft			
	Length	5 ft			
	Width	2-3 ft			
Sr No	Items	Description	Model/Make	Qty.	Requirement
1	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting)	Reverse Osmosis Anti-fouling membranes. Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 1000ltr/hr, Operating pressure: 10-11.5 bar, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm, Maximum applied pressure: 4.14 MPa	Hydranautics / Filmtech	1	RO membrane cleaning with chemicals (total descaling)

BOQ of RO Plant 180 Ltr/Hr					
GBES Jhalareen UC Beelywala, Jatoi					
Total cost	(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)				
	3 Months operation and maintenance (excluding electricity charges)				
	Trainings session of operators and an operating manual (5x3 ft panaflex)				
	One year warranty of Plant items				
Required size of the plant	Height	4-5 ft (as compact as possible)			
	Length	4 ft (as compact as possible)			
	Width	4 ft (as compact as possible)			
Sr No	Items	Description	Model/Make	Qty.	
1	Frame	The RO Plant shall be mounted on box iron frame), 50mmx 50 mmx 3mm, 8.0 g/cm ³ covered with carugated steel sheet of gauge 20 mounted on the frame on all sides and openable from front (joints sealed for water proofing and protection against rain). Total dimention of the frame should not exceed length:4', width:4' and height:5'	Approved	1	
2	Feed Pump	0.5 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China Model: CDLF	1 1	
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 10"x54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver) Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg	Pentair/Pall	1	
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 10"x54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver) Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Pentair/Pall Media: Deno Germany	1 1	
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1	
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1	

7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	0.5 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China Model: CDLF Series.	1
9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes, Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 180 ltr/hr, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm Size: L:40", Dia 8"	Toray, Japan	1
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel casing for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m ³ /hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m ³ /hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Lights	3 Led lights fixed inside the frame of plant	Approved brand	3
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed inside the frame of plant	General	1

BOQ of RO Plant 180 Ltr/Hr				
GGES Ali shah UC Kotla lal shah, Jatoi				
Total cost	(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)			
	3 Months operation and maintenance (excluding electricity charges)			
	Trainings session of operators and an operating manual (5x3 ft panaflex)			
	One year warranty of Plant items			
Required size of the plant	Height	4-5 ft (as compact as possible)		
	Length	4 ft (as compact as possible)		
	Width	4 ft (as compact as possible)		
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on box iron frame), 50mmx 50 mmx 3mm, 8.0 g/cm ³ covered with carugated steel sheet of gauge 20 mounted on the frame on all sides and openable from front (joints sealed for water proofing and protection against rain). Total dimentions of the frame should not exceed length:4', width:4' and height:5'	Approved	1
2	Feed Pump	0.5 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China	1

			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 10"×54", Flow capacity 2.1 m3/hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver)		
		Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg		
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 10"×54", Flow capacity 2.1 m3/hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver)		
		Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Media: Deno Germany	1
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m3/hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m3/hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	0.5 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China	1
			Model: CDLF Series.	
9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes, Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 180 ltr/hr, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm	Toray, Japan	1
		Size: L:40", Dia 8"		
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel casing for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m3/hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m3/hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2

10	Lights	3 Led lights fixed inside the frame of plant	Approved brand	3
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed inside the frame of plant	General	1

BOQ of RO Plant 180 Ltr/Hr				
GGES Basti Jhanga , Jatoi				
Total cost		(inclusive of: Supply, Onsite Assembling/Installation, Operationalization, Transportation, training of O&M committee operators and Taxes)		
		3 Months operation and maintenance (excluding electricity charges)		
		Trainings session of operators and an operating manual (5x3 ft panaflex)		
		One year warranty of Plant items		
Required size of the plant		Height	4-5 ft (as compact as possible)	
		Length	4 ft (as compact as possible)	
		Width	4 ft (as compact as possible)	
Sr No	Items	Description	Model/Make	Qty.
1	Frame	The RO Plant shall be mounted on box iron frame), 50mmx 50 mmx 3mm, 8.0 g/cm ³ covered with carugated steel sheet of gauge 20 mounted on the frame on all sides and openable from front (joints sealed for water proofing and protection against rain). Total dimintions of the frame should not exceed length:4', width:4' and height:5'	Approved	1
2	Feed Pump	0.5 m ³ /hr. 4 bar Vertical Multistage Centrifugal Pump, Single Phase motor 50Hz.	CNP Brand. Imported and Brand/warranteed New. Made in China	1
			Model: CDLF	1
3	Multimedia Rapid Sand Filter (Automatic backwash and resetting)	Vessel Size: 10"×54", Flow capacity 2.1 m ³ /hr, 4 bar operating pressure, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver)		
		Media: Silica Sand & Gravel. Total Media Height: 36", Gravel Bed Height: 10", Gravel Size: 10-12mm, Quartz Sand Bed Height: 32", Quartz sand Size: 6-8mm, 4-6mm, 2-4mm, 0.5-2mm, Total media weight: upto 120kg		
4	Activated Carbon Filter (Automatic backwash and resetting)	Vessel Size: 10"×54", Flow capacity 2.1 m ³ /hr, Rated Test Pressure: 10 Bar, Material: FRP Vessel	Pentair/Pall	1
		Automatic multiport valve with planar and corrosion resistant gasket for opening and closing. Service, backwash, and fast rinse functions. (equiped with a manual liver)		
		Media per tank: 3 cft Activated carbon media, Media weight: upto 50kg	Media: Deno Germany	1
5	Housing plus PPF Cartridge filter 5M (Jumbo)	5 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 5 micron	Taiwan/USA	1
6	Housing plus PPF Cartridge filter 1M (Jumbo)	1 Microns; 20" x 1 core filter. PE Housing, Flow Capacity 4.1 m ³ /hr, Rating: 1 micron	Taiwan/USA	1
7	Blending: Anti scalant dosing pump System	Anti scalant dosing pump with blending system including tank of capacity 20 Liters and complete in all specification : Capacity: 0.25 m ³ /hr	Etatron	1
8	High Pressure Pump (adjusted for the removal of TDS upto 6000 ppm)	0.5 m ³ /hr, 12 bar Vertical Multistage Centrifugal Pump - 01 Phase motor 50Hz, Max revolving speed: 2900 rpm	CNP Brand. Imported and Brand/Waranteed. Unboxing and assembling on site New. Made in China	1
			Model: CDLF Series.	

9	Reverse Osmosis membranes (Automatic Backwash with Auto Resetting) adjusted for the removal of TDS upto 6000 ppm	Reverse Osmosis Anti-fouling membranes, Membrane type: Thin film Polyamide-urea composite, No. of vessels: 1, Design output: 180 ltr/hr, Operating temperature: 25-45 degree celcius, Maximum feed turbidity: 1NTU, Max SDI: <5, Maximum Chlorination valve: <0.1ppm Size: L:40", Dia 8"	Toray, Japan	1
10	RO membrane casing	R/O Fiber Glass FRP pressure vessel casing for 1 element, Seal type: O-ring, Maximum operating pressure: 30 bar, Test pressure: 40 bar	Eurotec/Pall/Hitec	1
11	Pressure Gauges	Low pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	3
12	Pressure Gauges	High pressure Stainless steel gauges; glycerine filled. Stainless Steel	Wika China / Equivalent	2
13	Digital Flow meter	Digital Flowmeter for product water	Taiwan	1
14	Digital Flow meter	Digital Flowmeter for reject water	Taiwan	1
15	UV Light Filter with control box	Capacity: 1.2 m3/hr, Material of construction: SS, Length: 24"-36", Dia: 3", Inlet/outlet Dia: 1", Average useful life: 8000hr, UV Energy: 30000 micro watt second/sq.cm, Operating temperature: 25-40 degree celcius	Lamp & Quartz sleeve: Atlantic US / First Life / Equilent	1
16	Fittings	UPVC 80 schedule	Approved brand	1
Blending Line				
1	Filtration system	Capacity 0.25 m3/hr	EU/USA	1
Instrumentation and Controls				
1	Control box	Control box with contactor and overload safety circuits	Approved brand	1
2	Control switches	Single Phase power safety cut-off control circuit	Approved brand	2
3	Switches	On / Off switches; On and Trip indicator lights	Approved brand	1
4	Float switch	On raw water tak for submercible pump	Approved brand	1
5	Low level switch	Trip on low level of product water tank	Approved	1
6	TDS meter	TDS probe for TDS monitoring of Product Water	Approved brand	1
7	Solenoid Valve	Inlet & Flush solenoid valve	Approved brand	2
8	Safety control switch	To protect high pressure pump and membranes from over pressurization	Approved brand	1
9	Safety switches	Feed Water / Product Water / Water Tanks Low / High Level Switch Safeties to avoid dry pump run	Approved brand	2
10	Lights	3 Led lights fixed inside the frame of plant	Approved brand	3
10	Voltage stabilizer	10000 V capacity voltage stabilizer, input voltage 100-265 V, fixed inside the frame of plant	General	1

Delivery address:

Services/goods must be rendered/delivered directly to our field office in Muzaffargarh, to the addresses specified on the Purchase order/Contract.

Contracting: A Purchase agreement will be signed between the selected bidder and Civil Society Human and Institutional Development Programme (CHIP).

Tender Procedure

This call for tender file contains the following documents:

- this participation file
- an application form (Supplier registration form)
- a project of purchase agreement with its appendices: I (General Purchase Conditions), II (Technical Specifications) III (Tender : prices, delays...)

The participation procedure will be carried out in two stages:

- **presentation of application**
- **presentation of tender**

Tenderers are kindly asked to send a completed file. Files that would be incomplete will be rejected.

III.1) Presentation of application

- **How to present application?**

Companies interested in submitting a tender shall present their application at the same time of their tenders returning by mail to the person in charge of the contract (address above) before the deadline for reception of applications.

Applications and tenders should be sent in two envelopes corresponding to the two different sections of tenders:

- an envelope for application, entitled "Administrative proposal" with **the appendix I (General Purchase Conditions), application form (Supplier registration form), the participation file** which should be duly initialled, filled, signed and stamped by an authorised person and the required documents of the Tender file
- an envelope entitled "Tender proposal" with **the appendix III (technical and commercial offer here mention as "Tender") and appendix II (Technical specifications)** which should be duly initialled, filled signed and stamped by an authorised person and technical description's documents of the manufacturer for each item.

- **How will the bidders be selected?**

Applications will be examined according to two types of criteria in order:

- exclusion criteria: to check whether tenderers can take part in the tendering procedure
- selection criteria: to check the technical and professional capacity and economic and financial capacity of each tenderer having passed the exclusion stage.

Exclusion criteria:

Candidates or tenderers may be excluded from the selection and award procedures if they:

- are bankrupt or being wound up, are having their affairs administered by the courts, have entered into an arrangement with creditors, have suspended business activities, are the subject of proceedings concerning those matters, or are in any analogous situation arising from a similar procedure provided for in national legislation or regulations; or
- have been convicted of an offence concerning professional conduct by a judgment; or
- have been guilty of grave professional misconduct proven by any means which the contracting authorities can justify; or
- have not fulfilled their obligations relating to the payment of social security contributions or the payment of taxes in accordance with the legal provisions of the country in which they are established, or with those of the country of the contracting authority or those of the country where the contract is to be carried out; or
- have been the subject of a judgment for fraud, corruption, involvement in a criminal organisation or any other illegal activity detrimental to the Communities' financial interests; or
- have been declared, following another procurement procedure or grant award procedure financed by the Community budget, to be in serious breach of contract for failure to comply with their contractual obligations.

In addition, contracts may not be awarded to tenderers who, during the procurement procedure:

- subject to a conflict of interest;
- are guilty of misrepresentation in supplying the information required by the contracting authority as a condition of participation in the contract procedure or fail to supply this information.

By returning this participation file duly initialled and signed, tenderers state they are not in one or more situations described above and undertake to send to Civil Society Human and Institutional Development Programme (CHIP), within seven (7) calendar days following the receipt of Civil Society Human and Institutional Development Programme (CHIP)'s request, any additional document Civil Society Human and Institutional Development Programme (CHIP) considers necessary to perform its checks.

Administrative or financial penalties may be imposed by Civil Society Human and Institutional Development Programme (CHIP) on tenderers who are in one of the above cases of exclusion. The penalties imposed will be in proportion to the importance of the contract and the seriousness of the misconduct (on the minimal basis of Rs 250,000).

Selection criteria:

This part concerns the information given in the application form and the documents to attach. Each tenderer can also include any other document he wishes.

Selection criteria are in order of importance: financial viability, level of experience, ability to adapt to the requirements of the activities of Civil Society Human and Institutional Development Programme (CHIP) (working language, company structure), activity level and volume.

III.2) Presentation of tender offer

- **How to present tender offer?**

The companies are invited to transmit their best technical and economical tender respecting imperatively the terms and forms below. Tenders that would not respect those terms and forms will be rejected.

Language: all written documents shall be in English.

Currency unit: all prices shall be expressed in PKR inclusive of all applicable taxes.

General Purchasing Conditions: the "General Purchasing Conditions" of Civil Society Human and Institutional Development Programme (CHIP) are given in appendix I. Tenderers shall initial, sign and return this appendix I with the bid.

Tender validity: Tender Application shall remain valid for a period of One (01) calendar month/s after the deadline for reception of tenders.

Tender Presentation

Tenders will be made using and fulfilling the tables of the appendix III.

The obligatory fields to fulfil for each product are:

- Price of the product
- delivery time
- production country
- name and nationality of the manufacturer

Prices are firm and valid for the one (1) month duration unless and until the manufacturer announces any changes in the price of the product.

Prices for tender are Ex Works, including packing and packaging.

CHIP will ask the Supplier for direct delivery to its field office (final addressee of the products). The Supplier shall invoice a carriage surplus compared to the prices specified in the tender (appendix III). "Ad hoc" delivery time will also be determined. So the other costs the Supplier will be liable for as transportation, handling and insurance shall be given to Civil Society Human and Institutional Development Programme (CHIP) within the seven (7) days after order reception. Civil Society Human and Institutional Development Programme (CHIP) takes the right to compare those prices with others freight forwarder quotations.

Delivery times correspond in calendar days to the period from the date of reception of the order form until the date of the goods are ready to be sent to any place countrywide.

A technical documentation as well as a picture is required for each product.

Compliance: your basic offer shall be in any point strictly in accordance with the technical specifications specified in the appendix I. Moreover, tenderers can propose an alternative with the basic offer if they consider it economically and technically interesting for Civil Society Human and Institutional Development Programme (CHIP), by indicating very precisely the differences that it presents compared to the specification standards.

Sample: a sample or a demonstration of designated product(s) could be required by Civil Society Human and Institutional Development Programme (CHIP).

Precision inquiry

Any question or explanation requirement shall be written and addressed to the person in charge of the contract (address, fax and email above) before the date of the December 15, 2022.

Tenders submission

As mentioned previously the Tenderers shall present their application before their tenders by mail to the person in charge of the contract (address above) before the deadlines for reception of application and tenders. Tenderers will be excluded from the award procedure for this contract if tenders are received later than the above mentioned deadline for reception of tender.

Tenders should be sent in a single envelop corresponding to the second section of tenders:

- an envelop entitled "Tender proposal" with **the appendix III (Tender) and appendix II (Technical specifications)** which should be duly initialled, filled and signed by an authorised person and technical description's documents of the manufacturer for each item.
 - Technical documentation with a picture of product for which a tender has been submitted.
 - Certificates of origin would be appreciated.
- **How will the contract be awarded?**

Tenders will be assessed product by product. The award criterion which will be applied is the best compromise of quality/price/delivery time according to the needs specified in the call for tenders and favouring notion of complete lot. A particular attention will be given to the capacity of the supplier to propose prompt delivery.

Evaluation of tender offer will based on:

1. In line with CHIP General Purchasing Conditions
2. Unit Price
3. Specifications
4. Origin
5. Warranty
6. Quality & price of accessories and equipment provided
7. Payment terms & method
8. After-sale service
9. Delivery capabilities and delivery costs

Civil Society Human and Institutional Development Programme (CHIP) reserves the right to award the contract to one or more suppliers and will not have to justify its final decision. The tendering procedure shall not involve Civil Society Human and Institutional Development Programme (CHIP) in any obligation to award the contract. No compensation may be claimed by tenderers whose tender has not been accepted, including when Civil Society Human and Institutional Development Programme (CHIP) decides not to award the contract.

- **Notification of results**

Only the winning tenderer will be contacted by Civil Society Human and Institutional Development Programme (CHIP) to sign the framework agreement.

The other tenderers will be notified of the outcome of the call for tender by telephone or e-mail, up to three weeks after the tender submission deadline.

- **Other information**

Candidates may obtain additional information needed to compile their tenders. To obtain any further information, tenderers may contact: Mr. Muhammad Rafique (Manager Finance & Operations) & Tel: +92 333 5208223.

Date:

Place:

Name:

Function Title:

*Stamp

Signature preceded by the mention "read and approved" and seal of the company: